



Testing. Advising. Assuring.

6th December 2013

Our Ref: DF/144028/01

Mr. J. Hager
Vice President - International Sales

Hager Companies
139 Victor Street
St. Louis, MO 63104

Dear Mr Hager,

Re: Hager 3800U mortice case locksets for use with steel based doorsets.

Further to the above referenced matter, I am writing to provide confirmation of the scope of use currently included in our assessment report referenced WF No. 144028 Issue 5.

The report provides a positive appraisal of the Hager 3800U Series of lockset for use with timber based insulated doorsets for fire resistance periods of up to 60 minutes and steel based uninsulated doorsets for integrity periods of up to 240 minutes, with respect to the performance requirements of BS EN 1634-1: 2000/2008.

The specific lock models currently covered by the assessment are as follows:

3800U-55S/60S	Sash lock
3800U-55L/60L	Mortise latch
3800U-55M/60M	Mortise night latch
3800U-55T/60T	Mortise night latch
3800U-55F/60F	Mortise dead lock
3800U-55P/60P	Mortise escape lock
3800U-55B/60B	Mortise bathroom lock

For now I trust that the above confirmation is of assistance to you.

Yours sincerely,

A handwritten signature in black ink, appearing to read 'D. Forshaw', with a stylized flourish at the end.

D. Forshaw
Principal Certification Engineer
Technical Department